

संचालनालय, नगरीय प्रशासन एवं विकास, म.प्र., भोपाल
Directorate of Urban Administration & Development, M.P., Bhopal

पालिका भवन, शिवाजी नगर, भोपाल - ४६२०१६
Palika Bhawan, Shivaji Nagar, Bhopal - 462016

अग्नि शमन प्रकोष्ठ
Fire Cell

अनापत्ति प्रमाण पत्र
No Objection Certificate


जाचक क्रमांक Dispatch Number : 6000004963/FNOC/CIT/2020/6393

जाचक की तिथि Application Date : Dec 22, 2019 जाचक की तिथि / Dispatch Date : Jan 6, 2020

जाचक का नाम Applicant Name : PRAMOD KUMAR CHAJED KANWARTARA PUBLIC HR SEC SCHOOL

निम्नलिखित अग्निशमन सुरक्षा व्यवस्था करना अनिवार्य होगा :-

1. Access
2. Fire Exit
3. Down Comer
4. Hose Reel
5. Automatic Sprinkler System.
6. Yard Hydrant.
7. U.G. Tank with Draw off Connection.
8. Terrace Tanks.
9. Fire Pump
10. Terrace Pump.
11. First Aid Fire Fighting Appliances.
12. Pressurization System.
13. Auto Detection System.
14. Manua operated Electrical Fire Alarm System.
15. P.A. System with talk back facility.
16. Emergency Light.
17. Fire Exit Sign


Chairman
Shrikanwartara Chhajed
Charitable Trust


Principal
Kanwartara Pub.Hr.Sec.School
Mandleshwar Dist.Khargone(M.P.)
School Code - 50217